


JOHN OBERLIES CONSULTING ENGINEERS INC.
MECHANICAL • ELECTRICAL • PLUMBING

Proposed Dialysis Clinic for:
NOBLESVILLE EXPANSION
165 Sheridan Road
Noblesville, IN 46060



This is the place where a disclaimer statement can be placed.

Drafted By: NAS

Checked By: JWJ

Date Drawn: 07/20/10

Project #: 028012


REV #	DATE	REVISION DESCRIPTION
X/XX/XX	XXXXXXXXXXXXXXXXXX	

General Notes:

- These plans are diagrammatic in nature, and do not represent every necessary offset and fitting. Contractor shall install his work in a manner that will conform with the structure. Contractor shall avoid obstructions, preserve head room and maintain maximum clearance without additional cost to the owner.
- Sheet metal supply ductwork in concealed spaces shall be insulated with 1.5 lb density, fiberglass ductwrap.
- If any questions arise concerning the HVAC requirements of these documents, please contact John Oberlies Consulting Engineers (317) 656-3941, prior to bidding, fabrication or installation of equipment.
- Sheet metal transitions by Sheet Metal Contractor.

Plan Notes:

- Break existing 20x14 supply duct work. Cap and seal air tight.



MECHANICAL PLAN
SCALE: 1/4" = 1'-0"

M2.0

